

June 7, 2012

H2O VINYLDECK LTD.
8288 129th Street,
Surrey, BC
Canada V3W 0A6

**RE: QAI Evaluation of H2O VINYLDECK AQUA 60 and MESA 60 to
CAN/CGSB 37.54-95**

To Whom It May Concern:

Quality Auditing Institute Ltd. (QAI) conducted an evaluation of the H2O VINYLDECK AQUA 60 and MESA 60 PVC Roof and Walking Deck Membranes to the requirements of CAN/CGSB 37.54-95 as referenced in Section 9.26 'Roofing' of Division B of the National Building Code of Canada 2005 and 2010.

H2O VINYLDECK AQUA 60 and MESA 60 products are polyvinyl chloride membranes with a 1.5mm (60mil) nominal thickness and non-woven random polyester backing. The surface is embossed to provide a textured finish. The product is manufactured in standard roll sizes of 72 inches wide by 75 feet long.

The product is intended to be used as a waterproof membrane that is fully adhered to a continuous solid substrate, such as plywood or concrete decks and balconies that are subject to light pedestrian traffic. The membrane is intended to be fully adhered to the substrate with H2O VINYLDECK adhesives applied per published installation instructions.

The H2O VINYLDECK AQUA 60 and MESA 60 products are considered compliant with CAN/CGSB-37.54-95 as a Type 3, Class B membrane. For further details please refer to QAI evaluation report T786-1 dated June 7, 2012 or contact QAI at 604-527-8378.

Sincerely,
Quality Auditing Institute Ltd.



Kent Adamson, Project Manager